

**The following is a response to a question received during the pre-bid meeting held on August 8,2016 for the 49<sup>th</sup> Street, Brantner Road, Industrial Parkway Project.**

**Question:** Is there a warranty on the 6" concrete pavement being only 6" thick?

**Response:** Evans requires a 2-year warranty (see Sec 3.2.4 below). The thickness of the pavement was evaluated through ME pavement and given the base combined with the thickness of the concrete, everything should hold up. ME pavement results are available for review to any who wish to review it.

### **3.2.4 PROJECT WARRANTY**

The CONTRACTOR shall provide a two-year warranty for all construction beginning on the date of initial acceptance. All work that fails or deteriorates during the first or second year shall be replaced under this warranty. There will be no additional cost to the CITY for material, equipment, labor and/or traffic control for warranty work. Warranty work shall be completed in accordance with these contract specifications within 30 days of written notification by the CITY.