

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER
 City of Evans
Had the following Violations Identified During a Drinking Water Inspection

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

Our water system recently violated a drinking water requirement. Although this situation is not an emergency, as our customers you have a right to know what happened, what you should do, and what we are doing to correct this situation.

A routine drinking water inspection conducted on 2/18/2020 by the state drinking water program identified the following violations that may pose a risk to public health.

Identified Violation	Date Correction is Required	Steps We Are Taking
M613-Management: Failure to complete an Annual Backflow Report.	6/25/2020	The City is working with a contractor to conduct surveys and identify all backflow devices to be able to properly complete the Annual Backflow Report.
M610--Management: Failure to develop or implement a written backflow prevention and cross-connection control program.	6/25/2020	The City is currently revising our backflow prevention code and writing and implementing a backflow prevention and cross-connection control program.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During the inspection it was identified that we did not complete all monitoring/testing, were not monitoring correctly, or were monitoring at an inappropriate location. Therefore we cannot be sure of the drinking water quality during that time.

What does this mean? What should I do?

- There is nothing you need to do at this time. If a situation arises where the water is no longer safe to drink, you will be notified within 24 hours.

We anticipate resolving the problem by **7/25/2020**. For more information, please contact **Scott Sandridge** at ssandridge@evanscolorado.gov or **9704751181**, or **1100 37th Street**.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this notice in a public place or distributing copies by hand or mail.

This notice is being sent to you by: City of Evans - CO0162260

Date distributed: **5/27/2020**